

## MEDIUM-VOLTAGE CABLE DC HIGH POTENTIAL TEST

ESCO Group • ESCO Electric 3450 Third Avenue • PO Box 708 Marion, Iowa 52302 (319)377-6655 www.theESCOGroup.com

CM P AN
---------

CLIENT:ADDRESS:									
DATE:TEMPERATURE:			ATURE:	°F_ HUMIDITY:% EQPT. LOCATION:					
SUBSTATION	:				CIRCUIT ID:				
CA	ABLE SOURCE:_			CA	BLE TERMINATION POINT:				
MANUFACTURER:_				○ NON-SHIELDED	CONDUCTOR MATERIAL:INSTALLED IN:				
INSULATION TYPE:_				○ TAPE-SHIELDED	NO. OF CONDUCTORS:		AGE:		
% INSULATION:_				○ WIRE-SHIELDED	OPERATING VOLTAGE:	kV LI	ENGTH:	FT	
INSULATIO	N THICKNESS:_	MILS		ILS	RATED VOLTAGE:	kV	SIZE:	KCMIL	
CONNECTED	EQUIPMENT:_								
TIME MINUTES	TEST VOLTAGE	PHASE A μΑ	PHASE B μΑ	PHASE C μΑ Δ	PHASE IDENTIFICATION				
					PHASE A:■PHASE B: •	<u> </u>	PHASE C: Δ		
					VISUAL AND MECH	HANICAL INSP	ECTION		
					Compare cable data with drawings and sp	necifications. **	~ ~	N/A Note No.:	
					Inspect exposed sections of cables for phy		Ŭ Ŭ		
					Inspect compression-applied connectors cable match and indentation.	for correct	0 0	0	
					Inspect shield grounding, cable support, a	and terminations.	,		
					Verify that visible cable bends meet or ex manufacturer's minimum allowable bend	•	00	0	
					Inspect fireproofing in common cable are	as.			
					If cable are terminated through window-t transformers, inspect to verify that the neconductors are correctly placed and that correctly terminated for operation of pro-	eutral and ground the shields are	00	0	
					Inspect for correct identification and arra	ngements.			
					Inspect jacket and insulation condition.		00	0	
					Inspect bolted electrical connections for husing one of the following methods:	nigh resistance			
					Low Resistance Ohmmeter				
					COMMENTS:				
					DEFICIENCIES.				
					DEFICIENCIES:				
INSULATION RI (Megohms) @					Test Set Identifier:				
DECAY TO 5kV	(Seconds)								
SHIELD RESISTA	ANCE (Ohms)				Tested By:				